



MOD : UAC/P1-R2

Production code : 10402703-0-M-0

07/2025

Controller Programming Parameters

N.º PPC00377.04

Model

V2 / V6 - DIAMOND

EN							
Group	Param.	Description	Unit	Min.	Max.	Def.	Edit
Regulation	SEt	Set point	°C	-50.0	110.0	3.0	
	Hy	Differential	°C	0.1	25.5	2.0	3
	LS	Minimum set point	°C	-55.0	2.0	-50.0	0
	US	Maximum set point	°C	2.0	150.0	110.0	10
Probes	ot	Thermostat probe calibration	°C	-12.0	12.0	0.0	
Regulation	odS	Outputs delay at start up	min	0	255	0	1
	AC	Anti-short cycle delay	min	0	50	1	2
	Con	Compressor ON time with faulty probe	min	0	255	15	
	CoF	Compressor OFF time with faulty probe	min	0	255	30	
	CF	Temperature measurement unit				C	
	rES	Resolution				dE	
	dLy	Display temperature delay	min			00:00	
Defrost	idF	Interval between defrost cycles	h	0	120	8	
	MdF	(Maximum) length for first defrost	min	0	255	20	15
	dFd	Displaying during defrost				it	DEF
	dAd	Max display delay after defrost	min	0	255	30	
Fan	FnC	Fan operating mode				c-n	o-n
	FSt	Fan stop temperature	°C	-55.0	50.0	2.0	30
	FSU	Kind of action of fan				FoF	STD
Configuration	oA1	First relay configuration				FAn	
	PbC	Kind of probe				ntC	
	OnF	On/off key configuration				nu	OFF